

Report Transmission Cover Page

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Contact	Company	Address
Terry Walker	School District #35	20260 - 64th Ave Langley, BC V3A 4P7 Phone: (604) 534-3294 Fax: (604) 534-0841 Email: tewalker@sd35.bc.ca

Delivery	Format	Deliverables
Email - Merge Reports	PDF	COC / Test Report
Email - Single Report	PDF	COA
Email - Single Report	PDF	Invoice

Notes To Clients:

The information contained on this and all other pages transmitted, is intended for the addressee only and is considered confidential. If the reader is not the intended recipient, you are hereby notified that any use, dissemination, distribution or copy of this transmission is strictly prohibited. If you receive this transmission by error, or if this transmission is not satisfactory, please notify us by telephone.

Analytical Report

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Reference Number	1241565-25
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	Wix Brown / Hall DF by Rm 19 - S / 17.5 °C
Sample Matrix	Drinking Water

Analyte	Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments	
Metals Extractable						
Lead	Extractable	mg/L	0.00584	0.00001	0.01	Below MAC

Analytical Report

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Reference Number	1241565-26
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	Wix Brown / Hall DF by Rm 19 - F / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00180	0.00001	0.01	Below MAC

Analytical Report

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Reference Number	1241565-27
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	Wix Brown / Hall DF by Rm 31 - S / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00215	0.00001	0.01	Below MAC

Analytical Report

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Reference Number	1241565-28
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	Wix Brown / Hall DF by Rm 31 - F / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00058	0.00001	0.01	Below MAC

Analytical Report

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Reference Number	1241565-29
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	Wix Brown / Rm B5 - S / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00450	0.00001	0.01	Below MAC

Analytical Report

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7 Attn: Terry Walker Sampled By: Company:	Project ID: Project Name: Project Location: LSD: P.O.: Proj. Acct. code:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
---	---	--

Reference Number	1241565-30
Sample Date	November 27, 2017
Sample Time	NA
Sample Location	
Sample Description	Wix Brown / Rm B5 - F / 17.5 °C
Sample Matrix	Drinking Water

Analyte		Units	Result	Nominal Detection Limit	Guideline Limit	Guideline Comments
Metals Extractable						
Lead	Extractable	mg/L	0.00089	0.00001	0.01	Below MAC

Approved by: 
Mathieu Simoneau
Operations Manager

Data have been validated by Analytical Quality Control and Exova's Integrated Data Validation System (IDVS).

Generation and distribution of the report, and approval by the digitized signature above, are performed through a secure and controlled automatic process.

Methodology and Notes

Bill To: School District #35 20260 - 64th Ave Langley, BC, Canada V3A 4P7	Project ID: Project Name: Project Location: LSD: P.O.:	Lot ID: 1241565 Control Number: C0066157 Date Received: Nov 27, 2017 Date Reported: Nov 30, 2017 Report Number: 2246617
Attn: Terry Walker Sampled By: Company:	Proj. Acct. code:	

Method of Analysis

Method Name	Reference	Method	Date Analysis Started	Location
Trace Metals (extractable) in Water (Surrey)	US EPA	* Determination of Trace Elements in Waters and Wastes by ICP-MS, 200.8 <i>* Reference Method Modified</i>	Nov 28, 2017	Exova Surrey

References

US EPA US Environmental Protection Agency Test Methods

Guidelines

Guideline Description Health Canada GCDWQ
Guideline Source Guidelines for Canadian Drinking Water Quality, Health Canada, February 2017
Guideline Comments MAC = Maximum Acceptable Concentration
AO = Aesthetic Objective
OG = Operational Guideline for Water Treatment Plants
Refer to Health Canada GCDWQ for complete guidelines and additional drinking water information at www.hc-sc.gc.ca

The comparison of test results to guideline limits is provided for information purposes only. This is not to be taken as a statement of conformance / nonconformance to any guideline, regulation or limit. The data user is responsible for all conclusions drawn with respect to the data and is advised to consult official regulatory references when evaluating compliance.

Please direct any inquiries regarding this report to our Client Services Group or to the Operations Manager at the coordinates indicated at the top left of this page.

Results relate only to samples as submitted.

The test report shall not be reproduced except in full, without the written approval of the laboratory.